| Load Description | Control Class / Alert Class | Program Initiated | Alert On | Alert Off | Control Start | All Loads Controlled | Restoral Start | All Loads Restored |
|--|-----------------------------|---|---|-----------------------------|---|---|---|---|
| FULL LOAD CONTROL SCHEDULE | | | | | | | | |
| Alert Devices | Alert PA | 13:00 | 13:00 | 18:00 | n/a | n/a | n/a | n/a |
| Dairy Water Heaters | Class 4A | 13:55 | n/a | n/a | 14:00 | 14:00 | 18:30 | 19:00 |
| Air Conditioners ¹ | Classes 2, 2S, & 4B | 13:45 | n/a | n/a | 13:45 | 14:00 | 18:15 | 18:30 |
| Grain Drying | Class 24 | 13:40 | 13:45 | 18:05 | 13:55 | 13:55 | 18:05 | 18:05 |
| C & I Manual Standby, Peak Alert | Class 5B | 13:20 | 13:25 | 18:05 | 13:55 | 13:55 | 18:05 | 18:05 |
| Irrigation | Class 8 | 13:00 | 13:05 | 18:05 | 13:55 | 13:55 | 18:05 | 18:05 |
| DAILY ENERGY STORAGE SCHEDULE | | | | | | | | |
| Off-Peak ETS - Weekdays | Class 3-MF | 12:00 | n/a | n/a | 12:00 | 13:00 | 20:00 | 21:00 |
| Off-Peak ETS - All Days | Class 3-DLY | 12:00 | n/a | n/a | 12:00 | 13:00 | 20:00 | 21:00 |
| Off-Peak Large ETS - Weekdays | Class 3-A1 | 7:00 | n/a | n/a | 7:00 | 7:30 | 23:00 | 23:30 |
| Off-Peak EV Charging - Weekdays | Class 3-EV | 13:30 | n/a | n/a | 13:30 | 14:00 | 21:00 | 21:30 |
| ECONOMIC CONTROL SCHEDULE | | | | | | | | |
| Small Water Heaters | Class 1A | varied | n/a | n/a | 19:00 | Economic Control can occur anytime between Start and Restoral times, depending on market prices. 23:00 22:30 | | 23:00 |
| Large Water Heaters | Class 1B | varied | n/a | n/a | 18:00 | | | 0:00 |
| Dairy Water Heaters | Class 4A | varied | n/a | n/a | 18:00 | | | 23:00 |
| Air Conditioners | Classes 2, 2S, & 4B | varied | n/a | n/a | 18:00 | | | 22:30 |
| LOAD MODIFYING RESOURCE CONTROL SCHEDULE | | | | | | | | |
| Water Heater 4hr (small) | Class 1A | | At least 1 hour prior to control period | At end of control period | 5 minutes prior to MISO Scheduling Instruction Implementation Time | | 5 minutes after last hour of MISO Scheduling Instruction | 25 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5 hours total duration) |
| Water Heater 6hr (large) | Class 1B | LMR_ctrl_1_hour At leas LMR_ctrl_2_hour hour pri LMR_ctrl_3_hour control p LMR_ctrl_4_hour control p | | At end of control period | 5 minutes prior to MISO Scheduling Instruction Implementation Time | | 5 minutes after last hour of MISO Scheduling Instruction | 25 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5 hours total duration) |
| Auto Standby Generators | Classes 5A, 5A-W, & AE-1 | | At least 1 hour prior to control period | At end of control period | 5 minutes prior to MISO Scheduling Instruction Implementation Time | | 5 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5 hours total duration) | |

Control Times - Summer 2025

Notes:

1. Air conditioners cycling occurs randomly over 30 minutes with last air conditioner controlled by 2:15 p.m. Maximum total A/C control (saturation) begins at 2:00 p.m. and ends at 6:15 p.m.