


2022-23 Winter Control Times

Load Description	Control Class / Address	Alert On	Alert Off	Control Start	All Loads Controlled	Restoral Start	All Loads Restored
WINTER AM FULL LOAD CONTROL SCHEDULE							
Interruptible Heat (12hr+ backup)	Class 2 & 2W	n/a	n/a	6:55	6:55	9:55	10:55
WINTER PM FULL LOAD CONTROL SCHEDULE							
Peak Alert Notification Devices	Alert PA, Alert PA-W	15:55	20:05	n/a	n/a	n/a	n/a
Manual Standby Generators	Classes 5B, 5B-W	16:20	20:10	16:50	16:50	20:20	20:20
Dairy Water Heaters	Class 4A	n/a	n/a	16:55	16:55	20:00	20:00
Grain Drying	Class 24	16:45	21:10	16:55	16:55	21:10	21:10
DAILY ENERGY STORAGE SCHEDULE							
Off-peak Storage Mon-Fri	Class 3-MF	n/a	n/a	4:55	5:55	11:25	12:25
		n/a	n/a	14:55	15:55	21:25	22:25
Off-Peak EV Charging	Class 3-EV	n/a	n/a	13:30	14:00	21:00	21:30
ECONOMIC CONTROL SCHEDULE							
Water Heater 4hr (small)	Class 1A	n/a	n/a	17:00			21:00
Water Heater 6hr (large)	Class 1B	n/a	n/a	16:00		22:00	
Dairy Water Heaters	Class 4A	n/a	n/a	17:00		22:00	
Interruptible Heat (12hr+ backup)	Classes 2 & 2W	n/a	n/a	17:00		21:00	
LOAD MODIFYING RESOURCE CONTROL SCHEDULE (MAX GEN Capacity Resource)							
Residential Water Heater	Class 1A & 1B	At least 1 hour prior to control period	At end of control period	Load control can occur: - At anytime, at the discretion of MISO - With no less than 2 hour notification - At least once each season, up to 16 times annually		Restoral time will vary based on MISO's needs, but total continuous control duration will not exceed 4.5 hours (1A) or 6 hours (1B)	
Auto Standby Generators	Classes 5A, 5A-W, & AE-1	At least 1 hour prior to control period	At end of control period	Load control can occur: - At anytime, at the discretion of MISO - With no less than 2 hour notification - At least once each season, up to 16 times annually		Restoral time will vary based on MISO's needs, but total continuous control duration will not exceed 4.5 hours	