2023-24 Winter Control Times								
Load Description	Control Class / Address	Alert On	Alert Off	Control Start	All Loads Controlled	Restoral Start	All Loads Restored	
WINTER AM FULL LOAD CONTROL SCHEDULE								
Interruptible Heat	Class 2, 2W & 4B	n/a	n/a	6:55	6:55	10:00	11:00	
WINTER PM FULL LOAD CONTROL SCHEDUE								
Peak Alert Notification Devices	Alert PA, Alert PA-W	15:55	20:05	n/a	n/a	n/a	n/a	
Manual Standby Generators	Classes 5B, 5B-W	16:20	20:10	16:50	16:50	20:20	20:20	
Dairy Water Heaters	Class 4A	n/a	n/a	16:55	16:55	21:25	22:00	
Grain Drying	Class 24	16:45	21:10	16:55	16:55	21:10	21:10	
DAILY ENERGY STORAGE SCHEDULE								
Off-peak Storage Mon-Fri	Class 3-MF	n/a	n/a	4:55	5:55	11:25	12:25	
		n/a	n/a	14:55	15:55	21:25	22:25	
Off-Peak EV Charging	Class 3-EV	n/a	n/a	13:30	14:00	21:00	21:30	
		ECONO	MIC CONTRO	OL SCHEDULE				
Water Heater 4hr (small)	Class 1A	n/a	n/a	17:00	<<<<<<<	>>>>>>>	21:00	
Water Heater 6hr (large)	Class 1B	n/a	n/a	16:00	Economic Control can occur any time between Start 22:00		22:00	
Dairy Water Heaters	Class 4A	n/a	n/a	17:00	and Restoral times, depending on market prices. 22:00		22:00	
Interruptible Heat	Class 2, 2W & 4B	n/a	n/a	17:00	<		21:00	
LOAD MODIFYING RESOURCE CONTROL SCHEDULE								
Water Heater 4hr (small)	Class 1A	At least 1 hour prior to control period	control period	5 minutes prior to MISO Scheduling Instruction Implementation Time 5 minutes after last hour of MISO Scheduling Instruction		25 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5 hours total duration)		
Water Heater 6hr (large)	Class 1B	At least 1 hour prior to control period		5 minutes prior to MISO Scheduling Instruction Implementation Time		5 minutes after last hour of MISO Scheduling Instruction	155 minutes after last hour of MISO Scheduling Instruction (not to exceed 6 hours total duration)	
Auto Standby Generators	Classes 5A, 5A-W, & AE-1	At least 1 hour prior to control period					minutes after last hour of MISO Scheduling Instruction not to exceed 4.5 hours total duration)	

Last Revised: August 2023