Winter Control Times

Load Description	Control Class	Alert Start	Control Start	All Loads Controlled	Restoral Start	All Loads Restored
FULL LOAD CONTROL SCHEDULE - AM -- BILLING HOURS: 7AM-10AM --BILLING MONTHS: DECEMBER-FEBRUARY						
Interruptible Heating	Class 2, 2-W & 4B	n/a	6:55AM	7AM	10AM	11AM
FULL LOAD CONTROL SCHEDULE - PM -- BILLING HOURS: 5PM-8PM: --BILLING MONTHS: DECEMBER-FEBRUARY						
Peak Alert Notification Devices	Alert PA & PA-W	3:55PM	n/a	5PM	8:05PM	8:05PM
Manual Standby Generators	Class 5B	4:20PM	4:50PM	5PM	8:20PM	8:20PM
Dairy Water Heaters	Class 4A	n/a	4:55PM	5PM	8PM	8:30PM
Grain Drying	Class 24	4:45PM	4:55PM	5PM	9:10PM	9:10PM
DAILY ENERGY STORAGE CONTROL						
Off-Peak Monday-Friday Storage	Class 3-MF	n/a	4:55AM	5:55AM	11:25AM	12:25PM
		n/a	2:55PM	3:55PM	9:25PM	10:25PM
Off-Peak EV Charging	Class 3-EV	n/a	1:30PM	2PM	9PM	9:30PM
ECONOMIC CONTROL						
Water Heater 6 Hour (>50 gallon)	Class 1B	n/a	4PM	Economic Control can occur any time between Start and Restoral times, depending on market prices.		10PM
Water Heater 4 Hour (50 gallon)	Class 1A	n/a	5PM			9PM
Dairy Water Heaters	Class 4A	n/a	5PM			10PM
Interruptible Heating	Class 2, 2-W & 4B	n/a	5PM			9PM
LOAD MODIFYING RESOURCE (CAPACITY) CONTROL						
Water Heater 6 Hour (>50 gallon)	Class 1B	n/a		5 minutes prior to the start of the MISO scheduling instruction	5 minutes after last hour of MISO Scheduling Instruction	25 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5
Water Heater 4 Hour (50 gallon)	Class 1A	n/a		5 minutes prior to the start of the MISO scheduling instruction	95 minutes after the last hour of MISO scheduling instructions	155 minutes after last hour of MISO Scheduling Instruction (not to exceed 6
Auto Standby Generators	Classes 5A	n/a		5 minutes prior to the start of the MISO scheduling instruction	5 minutes after last hour of MISO Scheduling Instruction (not to exceed 4.5 hours total duration)	n/a